

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34104

1. OWNER W. Scoppatore ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS HC 62 Box 210 Newark Valley  
Eureka NV 89316  
 2. LOCATION NW 1/4 NE 1/4 Sec 9 T 18 R 55 E White Pine County  
 PERMIT NO. 46818 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material     | Water Strata | From | To  | Thick-ness |
|--------------|--------------|------|-----|------------|
| TOP Soil     |              | 0    | 2   | 2          |
| Clay sand    |              | 2    | 8   | 6          |
| Caliche      |              | 8    | 10  | 2          |
| Clay sand    |              | 10   | 92  | 82         |
| gravel sand  | X            | 92   | 103 | 11         |
| Clay sand    |              | 103  | 176 | 73         |
| gravel sand  | X            | 176  | 215 | 39         |
| Clay sand    |              | 215  | 221 | 6          |
| gravel sand  | X            | 221  | 230 | 9          |
| Clay sand    |              | 230  | 254 | 24         |
| Conglomerate |              | 254  | 260 | 6          |

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cased 260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 26 Inches To 0 Feet 260 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>16</u>          |                     | <u>.250</u>             | <u>0</u>    | <u>260</u> |

Perforations:  
 Type perforation factory slot  
 Size perforation 1/2 x 4  
 From 160 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 260 feet

9. WATER LEVEL  
 Static water level 38 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Drilling Contractor  
 Address P.O. Box 2487 Contractor  
EIKO NV  
 Nevada contractor's license number 0020684  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
 Signed Shane Bennett  
 By driller performing actual drilling on site or contractor  
 Date 10-4-96

Date started 9-25, 1996  
 Date completed 10-1, 1996

7. WELL TEST DATA

| TEST METHOD:  | <input checked="" type="checkbox"/> Bailer | <input checked="" type="checkbox"/> Pump | <input type="checkbox"/> Air Lift |
|---------------|--|--|-----------------------------------|
|               | G.P.M.                                     | Draw Down (Feet Below Static)            | Time (Hours)                      |
| <u>Bailer</u> | <u>50</u>                                  | <u>0</u>                                 | <u>6 hrs</u>                      |
| <u>Pump</u>   | <u>1500</u>                                | <u>72</u>                                | <u>4 1/2</u>                      |

RECEIVED  
 98 NOV 18 AM 10:45  
 STATE ENGINEERS OFFICE