WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65196
Permit No.
Basin C91

NOTICE OF INTENT NO. 31457

1. OWNER Rick Harris
MAILING ADDRESS 550 River Bend Road, Verdi, Nevada 89439
ADDRESS AT WELL LOCATION 550 River Bend Road, Verdi, Nevada 89439

2. LOCATION S/W ¼ S/W ¼ Sec. 15 T 19 N/S R 18 E Washoe County
PERMIT NO. 005527 (Issued by Water Resources) 38-672-02 (Parcel No.) Beli Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Boulders		0	20	
Clay & Rock		20	35	
Rock		35	40	
Clay & Boulders		35	90	
Cobble Stones		90	115	
Sandy Clay		115	125	
Gray Clay		125	140	
Gray Sandy Clay		140	180	
Gray Clay		180	195	
Brown Clay & Rock		195	247	
Gray Clay & Rock		247	263	
Brown Clay		263	270	
Gray Clay		270	275	
Gray Clay & Rock		275	325	
Gray Clay Streaks		325	335	
of Rock				

Date started December 1st, 19 96
Date completed January 15th, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	21	13 ft.	2 Hours

8. WELL CONSTRUCTION
Depth Drilled 335 Feet Depth Cased 335 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	335 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	335

Perforations:
Type perforation Factory
Size perforation 1/8"
From 0 feet to 115 Blank feet
From 115 feet to 135 Perf feet
From 135 feet to 295 Blank feet
From 295 feet to 335 Perf feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 335 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce Miller (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, Nevada 89507

Nevada contractor's license number issued by the State Contractor's Board 37915

Nevada driller's license number issued by the Division of Water Resources, the on-site driller # 1418

Signed Bruce Miller (By driller performing actual drilling on site or contractor)

Date January 16, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627