

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 05215
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28468
ASPEN HILLS CT.
GARDNERVILLE

1. OWNER HARRY TEDSEN ADDRESS AT WELL LOCATION ASPEN HILLS CT. GARDNERVILLE
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 3 T 12 N 19 E DOUGLAS County
 PERMIT NO. 19-032-23 ASPEN HILLS Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DG</u>		<u>0</u>	<u>120</u>	<u>120</u>
<u>DG (GRAVEL)</u>		<u>120</u>	<u>163</u>	<u>43</u>
<u>SANDY CLAY</u>		<u>163</u>	<u>181</u>	<u>18</u>
<u>GRANIT</u>		<u>181</u>	<u>204</u>	<u>23</u>
<u>SAND GRAVEL</u>	<input checked="" type="checkbox"/>	<u>204</u>	<u>215</u>	<u>11</u>
<u>GRANIT</u>		<u>215</u>	<u>216</u>	<u>1</u>
<u>DG</u>	<input checked="" type="checkbox"/>	<u>216</u>	<u>243</u>	<u>27</u>
<u>HARD DG (SHELLS OF WOOD)</u>	<input checked="" type="checkbox"/>	<u>243</u>	<u>251</u>	<u>8</u>
<u>SANDY CLAY</u>		<u>251</u>	<u>260</u>	<u>9</u>

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)
 From To
105/8 Inches 0 Feet 50 Feet
97/8 Inches 50 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>260</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 1/8
 From 180 feet to 220 feet
 From 240 feet to 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 260 feet

9. WATER LEVEL
 Static water level 87 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 9-23, 1996
 Date completed 10-8, 1996

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20+</u>	<u>-</u>	<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDICO EXPLORATION, INC Contractor
 Address 879 RITTER DR. GARDNERVILLE, NV 89410 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
 Signed David Keil
 By driller performing actual drilling on site or contractor
 Date 10-7-96

RECEIVED
 96 OCT 20 PM 1:16
 STATE ENGINEERS OFFICE