WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65274
Permit No.
Basin 083

NOTICE OF INTENT NO.

1. OWNER Joe Avignone
MAILING ADDRESS 6395 Opata Court
Sun Valley Nv 89433

ADDRESS AT WELL LOCATION 2380 Grissly Rd
Virginia City Highlands

2. LOCATION NW ¼ NE ¼ Sec. 32 T. 18 N/S R. 21 E. Storey County
PERMIT NO. (Issued by Water Resources) | Parcel No. 3-022-74 | Subdivision Name V.C. Highlands

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock		0	60	60 Ft
Pink clay		60	75	15 Ft
white clay		75	300	225 Ft
Fractured Rock + light sand.	✱	300	350	50 Ft

RECEIVED
96 OCT 30 AM 11:56
STATE ENGINEERS OFFICE

Date started Oct 4, 19 96
Date completed Oct 12, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	n/A	1 Hr

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
Inches		Feet	Feet
8 3/4 Inches		50 Feet	350 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	+1	350

Perforations:
Type perforation factory milled
Size perforation 3/32
From feet to feet
From 310 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 Ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 350 feet

9. WATER LEVEL
Static water level 175 Ft feet below land surface
Artesian flow n/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling Co. (Contractor)
Address P.O. Box 1345 Dayton (Contractor)
NV 89403
Nevada contractor's license number issued by the State Contractor's Board 4739A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Oct 18 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627