WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65346
Permit No.
Basin 071

NOTICE OF INTENT NO. 35852

1. OWNER Brad Shell
MAILING ADDRESS 5085 Grass Valley #230-10
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 4320 FORREST AVE.
~~Kimbre Road~~ ~~FORREST AVE.~~
Winnemucca, NV 89445

2. LOCATION ____ 1/4 NE 1/4 Sec. 7 T 35 N/S R 38 E Humboldt County
PERMIT NO. ____ Issued by Water Resources | 10-473-6 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Sand & Gravel		5	95	90
Boulders & Cobbles		95	164	69

Date started 2/18/97, 19__
Date completed 2/19/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 164 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8 Inches		0 Feet	164 Feet
____ Inches		____ Feet	____ Feet
____ Inches		____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	160

Perforations:
Type perforation Single row mill slot
Size perforation 1/8" x 3"
From 120 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 164 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow 0 G.P.M. 0 P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed Jerry Tompk
By driller performing actual drilling on-site or contractor

Date 2-26-97