

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28448

1. OWNER MIKE BRAWLEY ADDRESS AT WELL LOCATION 943 POWERS MINDEN, NV
 MAILING ADDRESS 943 POWERS MINDEN, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 19 T. 14 N. R. 20 E. DOUGLAS County
 PERMIT NO. 13-200-18 INDIAN HILLS Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	34	34
SANDY CLAY w/GRAVEL		34	47	13
SANDY CLAY		47	71	24
CLAY		71	78	7
SAND + GRAVEL		78	85	7
SANDY CLAY		85	96	11
COARSE SAND	✓	96	114	18
SANDY CLAY		114	125	11
SAND	✓	125	129	4
SANDY CLAY		129	131	2
SAND	✓	131	133	2
SANDY CLAY		133	139	6
SAND + GRAVEL	✓	139	150	11
SANDY CLAY		150	160	10

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 5/8 Inches	0 Feet 50 Feet
9 7/8 Inches	50 Feet 160 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	160

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 1/8 X 3
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level: 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0°F Quality GOOD

Date started 2-11 1997
 Date completed 2-14 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDCO EXPLORATION, INC Contractor
 Address 879 RITTER DR. Contractor
GARDNERVILLE, NV 89410
 Nevada contractor's license number 27673A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1726
 Division of Water Resources, the on-site driller
 Signed Paul J. Mow
 By driller performing actual drilling on site of contractor
 Date 2/14/97