

OFFICE USE ONLY
 Log No. 65364
 Permit No. 218
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30301

1. OWNER Bill Grenz ADDRESS AT WELL LOCATION S. Side of
 MAILING ADDRESS P.O. Box 850 Washington Ave Between 14th & 15th St
Elko, NV 89803

2. LOCATION NW 1/4 NE 1/4 Sec 17 T 32 S R 55 E Elko County
 PERMIT NO. 28-002-04 Elko Subdivision Name
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Silt Stone		2	20	18
Gray Granite & Quartz		20	400	380
Red Volcanic		400	540	140
Gray Granite	X	540	640	100

8. WELL CONSTRUCTION
 Depth Drilled 640 Feet Depth Cased 640 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
~~10 5/8~~ Inches ~~0~~ Feet ~~640~~ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1-1/2	640

Perforations:
 Type perforation Millslot
 Size perforation 3/16 x 3
 From 620 feet to 640 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 640 feet

9. WATER LEVEL
 Static water level 520 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Hackworth Drilling Inc.
 Address P.O. Box 850
Elko, NV 89803
 Nevada contractor's license number 020582
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1689
 Division of Water Resources, the on-site driller
 Signed Daniel Hersh
 By driller performing actual drilling on site or contractor
 Date 5-29-96

Date started 5-25 19 96
 Date completed 5-27 19 96

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow Test	60		3