

OFFICE USE ONLY
 Log No. 65378
 Permit No. 045
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30714

1. OWNER David J Lund ADDRESS AT WELL LOCATION 234
 MAILING ADDRESS P.O. Box 1374 Two Bottle Bar Lane
EIKO NV 87803 Pleasant Valley
 2. LOCATION NW 1/4 NW 1/4 Sec. 2 T. 2 N. R. 5 E EIKO County
 PERMIT NO. 23-009-04-8 Pleasant Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Loam</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>Gravel</u>		<u>4</u>	<u>7</u>	<u>3</u>
<u>Brown Clay</u>		<u>7</u>	<u>48</u>	<u>41</u>
<u>TAN Color CLAY</u>		<u>48</u>	<u>142</u>	<u>94</u>
<u>Loose Decompose Concrete</u>	<u>K</u>	<u>142</u>	<u>150</u>	<u>8</u>

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>12</u>	<u>150</u>

Perforations:
 Type perforation Slots
 Size perforation 3/16 x 3"
 From 130 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 52 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 52 feet to 150 feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

Date started 5-31, 1996
 Date completed 6-3, 1996

7. WELL TEST DATA

	TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Appx</u>	<u>25</u>		<u>4.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fentig Drilling Co Contractor
 Address P.O. Box 525 Contractor
EIKO NV 87803
 Nevada contractor's license number 31904
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1584
 Division of Water Resources, the on-site driller
 Signed Shouk Fentig
 By driller performing actual drilling on site or contractor
 Date 6-7-96