WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65537
Permit No.
Basin 107

NOTICE OF INTENT NO. 35124

1. OWNER Floyd Griffin
MAILING ADDRESS Box 12 Levining Calif 93541
ADDRESS AT WELL LOCATION Not Given Yet 10-761-15 Dessert Creek Rd. Wellington NV.

2. LOCATION NW ¼ NE ¼ Sec. 29 T 11 N/S R 24 E Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 11-761-15 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Large Boulders small Clay Seams		0	124	124
Small Round Boulders with Cemented Gravels		124	300	176
Cemented Gravels		300	340	400
Round small Boulders		340	410	70
Fractured Gravels	xx	410	460	50

RECEIVED 97 MAR 31 PM 2:53 STATE ENGINEER'S OFFICE

Date started 3-10, 19 97
Date completed 3-21, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12-15	45	4 HRS

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11¼ Inches		0 Feet	340 Feet
6⅝ Inches		34 Feet	460 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	13.03	.188	0	340
5 9/16	10.94	.188	320	460

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 280 feet to 300 feet
From 320 feet to 340 feet
From 400 feet to 420 feet
From 440 feet to 460 feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 340 feet

9. WATER LEVEL
Static water level 345 feet below land surface
Artesian flow G.P.M. 12-15 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat Dr. Contractor
Carson City NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hoek
By driller performing actual drilling on site or contractor
Date 3-24-97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627