WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65735
Permit No.
Basin 212

NOTICE OF INTENT NO. 10107

1. OWNER Royal Printing
MAILING ADDRESS 3274 W. Desert Inn Rd
Las Vegas, NV. 89102

ADDRESS AT WELL LOCATION Valley View Blvd N/o Spring Mtn Rd at Pioneer Way

2. LOCATION NW ¼ NW ¼ Sec. 17 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MO-2529 Issued by Water Resources
162-17-101-010 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-1

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill Gravelly Sand | N | 0 | 1 | 1 |
| Sandy Clay | N | 1 | 3 | 2 |
| Clayey Sand | N | 3 | 7 | 4 |
| Silty Sand | N | 7 | 9 | 2 |
| CALICHE w/ p.c. lenses | N | 9 | 13 | 4 |
| Sandy Clay w/ gravel | Y | 13 | 23 | 10 |
| CALICHE | Y | 23 | 24 | 1 |
| SILTY CLAY - gry | Y | 24 | 28 | 4 |

Date started December 21, 1994
Date completed same, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

RECEIVED
DEC 29 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 28 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 6½ | 0 | 28 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | PVC | sch 40 | 0 | 24 |
| | | | | |
| | | | | |

Perforations:
Type perforation slotted screen
Size perforation 0.10 inch
From 9 feet to 24 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 7
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 7 feet to 28 feet

9. WATER LEVEL
Static water level 12.71 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tim Aren c/o WTI Contractor
Address 3611 W. Tompkins Ave Contractor
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed By driller performing actual drilling on site or contractor
Date 12/20/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627