WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65765
Permit No.
Basin 101

NOTICE OF INTENT NO. 18451

1. OWNER GNS CONSTRUCTION
MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 6800 ERIN WAY

2. LOCATION NW 1/4 SE 1/4 Sec. 28 T 18 N/S R 29 E CHURCHILL County
PERMIT NO. Issued by Water Resources
0609179 Parcel No.
Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BROWN CLAY | | 0 | 24 | 24 |
| BROWN SAND | | 24 | 30 | 6 |
| BROWN CLAY | | 30 | 60 | 30 |
| BLACK CLAY | | 60 | 85 | 25 |
| GREY CLAY | | 85 | 98 | 13 |
| BLACK SAND | | 98 | 110 | 12 |
| GREY SAND | | 110 | 140 | 30 |
| GREY CLAY / SAND | | 140 | 150 | 10 |
| BROWN SAND | X | 150 | 160 | 10 |

RECEIVED 97 MAR 17 AM 11:21 STATE ENGINEER'S OFFICE

Date started 3/7/97, 19__
Date completed 3/7/97, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 1 hr. |

**8. WELL CONSTRUCTION**
Depth Drilled 160 Feet Depth Cased 160 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 10 3/4 | Inches | 0 | Feet | 50 | Feet |
| 6 1/8 | Inches | 50 | Feet | 160 | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | .188 | +1 | 160 |

**Perforations:**
Type perforation MACHINE SLOT
Size perforation .080
From 154 feet to 159 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

**9. WATER LEVEL**
Static water level feet below land surface
Artesian flow 1 G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. Contractor
Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed [signature] By driller performing actual drilling on-site or contractor
Date 3-14-97