WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65784
Permit No.
Basin 570

NOTICE OF INTENT NO. 35835

1. OWNER Belva Jones
MAILING ADDRESS 3530 Milligan Rd.
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
3530 Milligan Rd. Wmca, NV 89445

2. LOCATION NW 1/4 SW 1/4 Sec. 13 T 35N N/S R 37 E Humboldt County
PERMIT NO. (Issued by Water Resources) 13-581-05 (Parcel No.) (Subdivision Name)

**3. WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

**4. PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

**5. WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & gravel | | 120 | 160 | 40 |

Date started 12/23/96, 19__
Date completed 12/23/96, 19__

**7. WELL TEST DATA**

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15 | | 1 hr. |

**8. WELL CONSTRUCTION**
Depth Drilled ____ Feet Depth Cased 160 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | To |
|---|---|---|---|
| 6 1/8 Inches | | 120 Feet | 160 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5 5/8 | | .188 | 80 | 160 |

**Perforations:**
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 120 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

**9. WATER LEVEL**
Static water level 105 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 West Winnemucca Blvd. (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed ____ (By driller performing actual drilling on-site or contractor)
Date 12-30-96