WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65805
Permit No.
Basin 212

NOTICE OF INTENT NO. 9780

1. OWNER J.M. Peters OF NV. INC
MAILING ADDRESS 2800 W. SAHARA Suite 89 L.V. NV. 89102
ADDRESS AT WELL LOCATION FLAMINGO & Maville L.V. NV.

2. LOCATION S ½ SE ¼ Sec. 18 T 21 N/S R 61 E CLARK County
PERMIT NO. MB-2514 (Issued by Water Resources) 162-18-801-010 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Silt tan		0	3	3
Silty Sand w/ Gravel		3	4	1
Caliche		4	6	2
Sandy Silt		6	8½	2½
Conglomerate		8½	9½	1
Silty Sand		9½	12½	3
Silty Sand w/ Gravel		12½	18	5½
Conglomerate		18	20	2
Silty Sand w/ Gravel		20	23	3
Conglomerate	★	23	24	1
Silty Sand w/ Gravel		24	24½	½
Conglomerate		24½	33	8½
Silty Clay w/ Gravel		33	37	4

RECEIVED
APR 24 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started November 11, 1994
Date completed November 11, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 37 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8¾ Inches	0 Feet	37 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	—	—	0	37

Perforations:
Type perforation Slot
Size perforation 0.020
From 37 feet to 22 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 13
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 37 feet to 15 feet

9. WATER LEVEL
Static water level 24 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature 71 °F Quality TURBID

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Scott Davis (Contractor)
Address 3711 Resulus (Contractor)
L.V. NV. 89102
Nevada contractor's license number issued by the State Contractor's Board ~~M-1430~~
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1930
Signed (By driller performing actual drilling on site or contractor)
Date 12-3-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627