WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 658716
Permit No.
Basin 212

NOTICE OF INTENT NO. 11942

1. OWNER William Reynolds
MAILING ADDRESS c/o Converse Consultants 4670 S. Polaris Ave., Las Vegas
ADDRESS AT WELL LOCATION NE. Corner Las Vegas Blvd. S. & Harmon Las Vegas, Nevada.
2. LOCATION SW ¼ NW ¼ Sec. 21 T. 21 (N)/S R. 61 E. Clark County
PERMIT NO. W-2240 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt.		0	.5	.5'
Silty Sand tr. gravel		.5	7	6.5'
Sandy Silt		8	13	5'
gravelly sand		13	18	5'
Caliche		18	24	6'
Silty clay		24'	31	7'
Sandy clay tr. gravel		31	39	8'
caliche		39'	39.5	.5
T.D. = 39.5'				

RECEIVED
FEB 16 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2. 11, 1993
Date completed 2. 11, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 39.5 Feet Depth Cased 39.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	39.5 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.7 lbs	SCH. 40	0	39.5

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 9.5 feet to 39.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0 - 7.5 / 5.5-7.5 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 7.5 feet to 39.5 feet

9. WATER LEVEL
Static water level 24 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc
Address 4670 S. Polaris Ave. Las Vegas, NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1817
Signed LeBlanc
By driller performing actual drilling on site or contractor
Date 02.16.93

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627