

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log 165900
 Permit 2129
 Basin 058
 NOTICE OF INTENT NO. 32921

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Mike & Debbie Odette ADDRESS AT WELL LOCATION 58 miles South of BM on Antelope Road
 MAILING ADDRESS HC61 Box 128 Battle Mountain, NV 89445
 Battle Mountain, NV 89820

2. LOCATION NE 1/4 NW 1/4 Sec. 16 T 25N N/S R 42 E Lander County
 PERMIT NO. 62621 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Topsoil		0	4	4
Sand & gravel		4	38	34
Brown Clay		38	42	4
Sand & gravel		42	73	31
Soft brown clay		73	78	5
Sand & gravel		78	81	3
Brown clay		81	94	13
Sand & gravel		94	97	3
Brown clay		97	109	12
Sand & gravel		109	136	27
Sandy clay		136	138	2
Sand & gravel		138	184	46
Brown clay w/sand		184	185	1
Sand & gravel		185	235	50
Sand w/clay layers		235	239	4
Sand & gravel		239	325	86
Sandy clay		325	335	10
Sand & gravel		335	340	5
Sandy clay		340	346	6
Sand & gravel		346	348	2
Sandy clay		348	355	7
Sand & gravel		355	363	8
Sandy clay		363	372	9
Sand & gravel		372	380	8
Sandy clay		380	400	20

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 385 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 400
26 Inches 0 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+2	140
16		.250	340	360
16		.250	380	385

Perforations:
 Type perforation Double row mill slot
 Size perforation 1/8 X 3
 From 140 feet to 260 feet
 From 260 feet to 280 feet
 From 280 feet to 300 feet
 From 300 feet to 380 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 400 feet

9. WATER LEVEL
 Static water level 148 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 West Winnemucca Blvd. Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1572
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 3-10-97

Date started 2/21/97, 19____
 Date completed 2/22/97, 19____

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input checked="" type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>3200</u>	<u>180'</u>	<u>6</u>	
<u>27</u>	<u>18</u>	<u>16</u>	
<u>97</u>	<u>31</u>	<u>16</u>	
<u>22</u>	<u>18</u>	<u>16</u>	