WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

PPW-91
STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65901
Permit No.
Basin 061

NOTICE OF INTENT NO. 18877

1. OWNER BARRICK GOLDSTRIKE MINES, INC.
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89802

ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE SITE

2. LOCATION SE ¼ NW ¼ Sec. 30 T. 36 N/S R. 50 E EUREKA County
PERMIT NO. 55150 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Municipal/Industrial (Mining) [ ] Irrigation [ ] Monitor [ ] Test [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRANITE		0	890	890
GRANITE/GRAY CLAY		890	900	10
GRANITE		900	1170	270
GRANITE/GRAY CLAY		1170	1180	10
GRANITE		1180	1200	20
GRANITE/GRAY CLAY		1200	1205	5
GRANITE		1205	1285	80
GRANITE/GRAY CLAY		1285	1290	5
GRANITE		1290	1305	15
GRANITE/GRAY CLAY		1305	1310	5
GRANITE		1310	1350	40
GRANITE/GRAY CLAY		1350	1360	10

Date started APRIL 17, 19 97
Date completed MAY 5, 19 97

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75	845	ONE HOUR
60		
60		
60		

8. WELL CONSTRUCTION
Depth Drilled 1,360 Feet Depth Cased 1,340 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17.5	Inches	0	Feet	70	Feet
9.875	Inches	70	Feet	1360	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12.75	27.4	.250	0	70
6.625	17.02	.250	+1	1340

Perforations:
Type perforation LOUVERED
Size perforation .125
From 540 feet to 1340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 1360 feet

9. WATER LEVEL
Static water level 580.3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 68 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address P.O. BOX 5279 (Contractor)
ELKO, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
Signed JOHN VIERGUTZ John Viergutz
(By driller performing actual drilling on site or contractor)
Date MAY 5, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627