WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65942
Permit No.
Basin 043

NOTICE OF INTENT NO. 33245

1. OWNER Rick McDowell
MAILING ADDRESS 2121 Cartwright Rd. Reno, NV 89511
ADDRESS AT WELL LOCATION 2111 Cartwright Rd. Reno, NV 89511

2. LOCATION NE ¼ SE ¼ Sec. 32 T 18 N N/S R 21 East Storey County
PERMIT NO. (Issued by Water Resources) 03-092-89 (Parcel No.) Virginia City Highlands (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC [X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	10	10
Weathered Granite		10	15	5
Green & gray clay stone		15	30	15
Weathered granite fractured soft		30	35	5
Brown clay w/brown clay stone soft		35	40	5
Weathered granite		40	55	15
brown clay		55	60	5
Weathered granite hard		60	80	20
Salt & pepper granite Hard		80	150	70
Weathered granite Hard		150	170	20
Green, white & purple granite hard	X	170	242	72
T.D. 242'				

Date started March 24, 1997
Date completed March 26, 1997

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 hours

8. WELL CONSTRUCTION
Depth Drilled 242 Feet Depth Cased 242 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	50 Feet
8 1/2 Inches	50 Feet	242 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1½	242

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 222 feet to 242 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 242 feet to 50 feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, Inc. (Contractor)
Address 1800 ½ Frazer Ave. (Contractor)
Sparks, NV 89431
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date March 31, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627