VD-97-26

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65954
Permit No.
Basin 061

NOTICE OF INTENT NO. 36029

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ NE ¼ Sec. 30 T 36 (N)S R 50 E EUREKA County
PERMIT NO. M/O-565 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAYS, SAND, GRAVEL				
CARLIN FORMATION		0	385	385
BROWN OXIDIZED VINNINI		385	445	60
GRAY OXIDIZED VINNINI		445	640	195
HARD GRAY ROCK		640	860	220

Date started MARCH 11, 19 97
Date completed MARCH 15, 19 97

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		15 MIN
28		30 MIN
25		45 MIN
22		1 HOUR

8. WELL CONSTRUCTION
Depth Drilled 860 Feet Depth Cased 857 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17 Inches		0 Feet	40 Feet
9-7/8 Inches		40 Feet	860 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12.75	33.38	.250	0	40
6.625	17.02	.250	+2	857

Perforations:
Type perforation LOUVERED
Size perforation .125
From 116.5 feet to 857 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 102.8
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 860 feet to 102.8 feet

9. WATER LEVEL
Static water level 511.2 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 65 °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2039

Signed DENNY ROBBLEE Denny Robblee
By driller performing actual drilling on site or contractor
Date MARCH 2, 1997

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

ORIGINAL

(O)-627