WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66197
Permit No.
Basin 289

NOTICE OF INTENT NO. 26993

1. OWNER Dhary Rasher Const
MAILING ADDRESS [illegible]
ADDRESS AT WELL LOCATION 500 WASHOE DRIVE

2. LOCATION SE ¼ SE ¼ Sec. 23 T. 17 N/S R. 19 E. WASHOE County
PERMIT NO. 50-235-05
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Brown Clay		5	14	9
Fine to Coarse Sand	—	14	47	37
Blue Clay		47	52	5
Strata Sand & gravel	—	52	99	47
Coarse Sand & gravel	—	99	117	18
Brown Clay		117	120	3

Abandon Existing 5" well
Depth 51 Ft. Casing Broken
CK Rock 1 at 18 ft.

Plugged By Well
Log 126329

RECEIVED
96 MAY -7 PM 12:36
STATE ENGINEER'S OFFICE

Date started 10-17, 1995
Date completed 10-18, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	NA	1

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	120

Perforations:
Type perforation Factory Mill
Size perforation 3/32
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured Boundary
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eglo Drilling Co.
Contractor
Address P.O. Box 1345 Dayton Nev.
Contractor

Nevada contractor's license number issued by the State Contractor's Board 47394
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 590
Signed [signature]
By driller performing actual drilling on site or contractor
Date 10-18-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627