WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66330
Permit No.
Basin 218

NOTICE OF INTENT NO. 12001

1. OWNER THE MARK GROUP
MAILING ADDRESS 2975 S RAINBOW SUITE 6 LV. NV 89102

ADDRESS AT WELL LOCATION NDOT MAINT. GLENDALE NV

2. LOCATION SW ¼ NW ¼ Sec. 2 T. 15 N/S R. 66 E. County
PERMIT NO. MO-2135 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay w/ some fines & sands | | 0 | 30 | |
| EXSISTING 4" WELL WAS ABANDON. OVER DRILLED & NEW 8" STAINLESS STEEL SCREEN & LOW CARBON STEEL CASED WELL WAS INSTALLED TO REPLACE THE 4" PVC WELL. | | | | |

RECEIVED
DEC 17 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-13, 1993
Date completed 11-13, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 13 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8.5 | Low Carbon | S-40 | 0 | 10 |
| | | | | |
| | | | | |

Perforations:
Type perforation Slotted Screen (S.S.)
Size perforation .020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 6
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 8 feet to 30 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weber Environmental (Contractor)
Address 4301 S. Valley View #21 Lv. NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0035639
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1910
Signed (By driller performing actual drilling on site or contractor)
Date 12-13-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627