

Well #2

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

### WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 66368  
Permit No. 212  
Basin 212

OFFICE USE ONLY

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 9732

1. OWNER Valley Hospital/Pepper Jaynes  
MAILING ADDRESS \_\_\_\_\_

ADDRESS AT WELL LOCATION  
Valley Hospital

2. LOCATION NW 1/4 SW 1/4 Sec. 33 T. 20 N/S R. 61 E. Clark County

PERMIT NO. DM1002 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  dewatering/PROPOSED USE  
 Deepen  Abandon  Other dewaterer  Domestic  Municipal/Industrial  Irrigation  Test  Monitor  Stock  Air  Other auger

WELL TYPE  
 Rotary  RVC

### 6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy gravel		0	11	11
cemented congl.		11	12	1
brown clay		12	14	2
cemented congl.		14	24	10
brown clay		24	30	6

8. WELL CONSTRUCTION  
Depth Drilled: 30 Feet Depth Cased: 30 Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
24 Inches. 0 Feet 30 Feet  
Inches. \_\_\_\_\_ Feet  
Inches. \_\_\_\_\_ Feet

### CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	+1	30

RECEIVED  
NOV 19 1992  
Div. of Water Resources  
Branch Office - Las Vegas, NV

Performations: machine slot  
Type perforation 1/4" x 2 x 8 rows 16  
Size perforation 15 feet to 30 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal: \_\_\_\_\_  
Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 11 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling, Inc. Contractor  
Address 4847 So. Valley View  
Las Vegas, Nev. 89103 Contractor

Nevada contractor's license number 0018917  
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1301

Signed [Signature]  
by driller performing actual drilling on site or contractor  
Date 11-13-92

Date started \_\_\_\_\_ 19\_\_\_\_  
Date completed \_\_\_\_\_ 19\_\_\_\_

### 7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift  
G.P.M. Draw Down (Feet Below Static) Time (Hours)