

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 12126

1. OWNER LUMK READI MIX ADDRESS AT WELL LOCATION 501 N. PARKSON RD
 MAILING ADDRESS 501 N. PARKSON ROAD
HENDERSON NV 89015
 2. LOCATION NE 1/4 SW 1/4 Sec 2 T 22 N R 62 E CLARK County
 PERMIT NO. MD-2351 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE MW-3
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SILTY SAND</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>SILTY SANDY CLAY</u>		<u>8</u>	<u>14</u>	<u>6</u>
<u>CEMENTED SAND/GRAVEL</u>		<u>14</u>	<u>19</u>	<u>5</u>
<u>SILTY SAND</u>		<u>19</u>	<u>26</u>	<u>7</u>
<u>SANDY CLAY</u>		<u>26</u>	<u>35</u>	<u>9</u>

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 35 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.020
 From 15 feet to 35 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 0-11'-11-13' BENTONITE Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 13 feet to 35 feet

9. WATER LEVEL
 Static water level 23.0 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMAS HIGH Contractor
 Address 4670 SOUTH POLARIS
LAS VEGAS NV 89103 Contractor
 Nevada contractor's license number _____
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
 Signed Thomas A. High
 By driller performing actual drilling on site or contractor
 Date JAN 13, 1997

Date started NOV 3, 1993
 Date completed NOV 3, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
 NOV 14 1994
 DIVISION OF WATER RESOURCES
 2500 SOUTH MAIN ST.
 LAS VEGAS, NV 89102