


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 66723  
 Permit No. 1162  
 Basin. 1162



*Fixed -*  
 July 10, 1997

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 15335

1. OWNER James Richmond ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Pahrump, NV 89041 Gally St. Pahrump, NV  
 2. LOCATION SE 1/4 NE 1/4 Sec. 30 T. 19 N/S R. 53 E. E County \_\_\_\_\_  
 PERMIT NO. 29-492-13 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name unknown

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Clay</u>		<u>0</u>	<u>7</u>	<u>7</u>
<u>dec. Caliche</u>		<u>7</u>	<u>13</u>	<u>6</u>
<u>brown Clay</u>		<u>13</u>	<u>47</u>	<u>34</u>
<u>Caliche</u>		<u>47</u>	<u>49</u>	<u>2</u>
<u>brown Clay</u>	<u>X</u>	<u>49</u>	<u>135</u>	<u>86</u>
<u>Caliche</u>	<u>X</u>	<u>135</u>	<u>137</u>	<u>2</u>
<u>brown Clay</u>	<u>X</u>	<u>137</u>	<u>1160</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 1160 Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>N/A</u>	<u>1.88</u>	<u>0</u>	<u>1160</u>
		<u>2.50 PVC</u>		

Perforations:  
 Type perforation Factory  
 Size perforation 3/4 x 1160  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 120 feet to 1160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 1160 feet

9. WATER LEVEL  
 Static water level 54' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.F.  
 Water temperature Cold °F Quality good

Date started July 8, 1997  
 Date completed July 9, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>0</u>	<u>1/2 Hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Larry's Water Well Service Contractor  
 Address P.O. Box 3392 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916  
 Signed Larry Jenkins  
 By driller performing actual drilling on site or contractor  
 Date July 10, 1997