WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 668838
Permit No.
Basin 213

NOTICE OF INTENT NO. 14067

1. OWNER (see for)
MAILING ADDRESS 5070 Arville st su-7 LV NV 89119

ADDRESS AT WELL LOCATION Cecil's Market, LAUGHLIN, NV

2. LOCATION SE ¼ NW ¼ Sec. 13 T. 32 N OR S 66 E CLARK County

PERMIT NO. mo - 2438 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| poorly graded sand | | 0 | 20 | |
| clay | | 20 | 22 | |
| poorly graded sand | | 22 | 40 | |
| gravel | | 40 | 41 | |
| sand | | 41 | 43 | |

RECEIVED APR 3 1995 Div. of Water Resources Branch Office - Las Vegas, NV

Date started 3-2, 19 95
Date completed 3-2, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 43 Feet Depth Cased 43 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 7 | 0 | 43 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.5 | PVC | Sch 80 | 0 | 40 |
| | | | | |
| | | | | |

Perforations:
Type perforation Slotted screen
Size perforation -020
From 40 feet to 43 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 36
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 38 feet to 43 feet

9. WATER LEVEL
Static water level 24 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weber Environmental (Contractor)
Address 4301 S Valley View #21 (Contractor) LV NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0020356 33
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1847
Signed (By driller performing actual drilling on site or contractor)
Date 3-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627