WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY.
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66908
Permit No.
Basin 212

NOTICE OF INTENT NO. 10598

1. OWNER PAYLESS, INC
MAILING ADDRESS 9275 S.W. Pemton Lane
Wilsonville Oregon 97070

ADDRESS AT WELL LOCATION ~~N.W. CORNER~~
500' north of Sahara Ave on East side of Valley View Blvd, Las Vegas NV

2. LOCATION SE ¼ SW ¼ Sec. 6 T 21 S R 61 E CLARK County

PERMIT NO. 2185 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt / Fill		0	3	3
Clayey Silt w/gravel		3	6	3
Clay w/silt		6	13	7
Caliche		13	14½	1½
Silty Clay		14½	21½	7
Clayey Silt		21½	25	3.5

RECEIVED
SEP 24 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8-28 1992
Date completed 8-28 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.070		0	25

Perforations:
Type perforation Factory Slotted
Size perforation 0.020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 3 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc / Converse Consultants (Contractor)
Address 4670 S Polaris Ave (Contractor)
Las Vegas NV 89108
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed (By driller performing actual drilling on site or contractor)
Date 9-18-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627