

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16804

1. OWNER LUP ADDRESS AT WELL LOCATION 5 Decade  
 MAILING ADDRESS LU LV 4420 5 Decade  
 2. LOCATION S 1/4 Sec 34 T. 21 N. R. 6 E. County RACON  
 PERMIT NO. DW 1039 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>		<u>0</u>	<u>6"</u>	<u>6"</u>
<u>F.H. Dirt</u>		<u>6"</u>	<u>3</u>	<u>2 1/2</u>
<u>Clay w/ Sand</u>		<u>3</u>	<u>17</u>	<u>14</u>
<u>Clay</u>		<u>17</u>	<u>15</u>	<u>1</u>
<u>Clay w/ Sand</u>		<u>18</u>	<u>24</u>	<u>6</u>
<u>Clay w/ Sand &amp; gravel</u>		<u>24</u>	<u>37</u>	<u>13</u>
<u>Clay</u>		<u>37</u>	<u>45</u>	<u>8</u>

8. WELL CONSTRUCTION  
 Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 45 Feet  
 Inches Feet Feet Feet  
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>11</u>	<u>5/16</u>	<u>0</u>	<u>45</u>

Perforations:  
 Type perforation Slot  
 Size perforation .803  
 From 25 feet to 45 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 0 feet to 45 feet

9. WATER LEVEL  
 Static water level 26 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.1 °F Quality good

RECEIVED  
 NOV 20 1995  
 DCNR/DWR  
 LAS VEGAS OFFICE

Date started 10-20 1995  
 Date completed 10-20 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GLD  
 Address 536 E. Mainland  
Ontario CA  
 Nevada contractor's license number 001246  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1965  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 11-17-95