

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27425

1. OWNER SHELL SERVICE STATION ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 690 KEISTONE AVE. \_\_\_\_\_  
RENO NV \_\_\_\_\_  
 2. LOCATION SE 1/4 NE 1/4 Sec 10 T 19 R 19 E WASHOE County \_\_\_\_\_  
 PERMIT NO. M/10 1119 Parcel No. 56-221-18 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other TUBEK

6. LITHOLOGIC LOG MW-5#2

Material	Water Strata	From	To	Thick-ness
<u>CLAY</u>		<u>0'</u>	<u>5'</u>	
<u>CLAYS, GRAVELS</u>		<u>5'</u>	<u>10'</u>	
<u>CLAYS, SANDS, GRAVELS</u>		<u>10'</u>	<u>25'</u>	
<u>CLAYS, SANDS</u>		<u>25'</u>	<u>35'</u>	
<u>CLAYS, GRAVELS</u>		<u>65'</u>	<u>75'</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 75' Feet Depth Cased 75' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6" Inches To 0' Feet 75' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0'</u>	<u>75'</u>

Perforations:  
 Type perforation FACTORY  
 Size perforation 270  
 From 50' feet to 75' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 45'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 49' feet to 55' feet

9. WATER LEVEL  
 Static water level 65' feet below land surface  
 Artesian flow NE G.P.M. NA P.S.I.  
 Water temperature COLD °F Quality NA

Date started 07/14, 19 97  
 Date completed 05/15, 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ANDRESEN DRILLING Contractor  
 Address 1635 BELFORD RD. Contractor  
RENO, NV 89509  
 Nevada contractor's license number 34525  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5/28/97

RECEIVED  
 97 JUL 17 AM 11:21  
 STATE ENGINEERS OFFICE