

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 07624  
Permit No. 105  
Basin 105

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28458

1. OWNER JAMES SHUGREN ADDRESS AT WELL LOCATION 216 MTN REACH COURT GENOA, NV  
MAILING ADDRESS Box 439 GENOA NV 89411  
2. LOCATION NW 1/4 SW 1/4 Sec 3 T. 12 S. R. 19 E DOUGLAS County DOUGLAS  
PERMIT NO. 19-042-22 Subdivision Name FOOTHILL  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CONST FILL		0	4	4
V Big Blocks w MINOR SAND		4	20	16
Loose DG w AB COBBLES		20	160	140
V COMPACT DG		160	200	40
SOFT DG w WATER STAINED CUTTINGS	X	200	250	50

8. WELL CONSTRUCTION  
Depth Drilled 250 Feet Depth Cased 250 Feet  
HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 0 Feet 100 Feet  
10 Inches 100 Feet 250 Feet  
.....Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13+</u>	<u>.108</u>	<u>+2</u>	<u>250</u>

Perforations:  
Type perforation Sawcut  
Size perforation 3 x 3/32  
From 190 feet to 250 feet  
From.....feet to.....feet  
From.....feet to.....feet  
From.....feet to.....feet  
From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 100 feet to 250 feet

9. WATER LEVEL  
Static water level 80 feet below land surface  
Artesian flow No G.P.M. P.S.I.  
Water temperature 84.9 °F Quality ?

Date started 7/8, 1997  
Date completed 7/11, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>		<u>3</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name NEVADA DRILLING, INC. Contractor  
Address 75 LEWERS CRK RD CARSON CITY, NV 89704 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 13697A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
Signed Joe Reich  
By driller performing actual drilling on site or contractor  
Date 8/7/97

RECEIVED  
97 AUG 14 AM 11:42  
STATE ENGINEERING OFFICE