

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER CARSTEN REESE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HC 65 BOX 55 110 GILLMAN CIRCLE
GILLMAN SPRINGS AUSTIN NEV 89310 GILLMAN SPRINGS AUSTIN NEV 89310
 2. LOCATION SW 1/4 NE 1/4 Sec 10 T 16 N/S R 44 E LANDER County
 PERMIT NO. 04-033-08 GILLMAN SPRINGS RANCH
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CLY		0	15	15
GRAVEL		15	18	3
BROWN CLY		18	26	8
GRAVEL		26	34	9
BROWN CLY		34	42	7
COARSE SAND		42	46	4
BROWN CLY		46	75	29
GRAVEL	Y	75	83	8
TAN CLY		83	105	22
GRAVEL	Y	105	112	7
TAN CLY		112	148	36
GRAVEL	X	148	169	21
BROWN CLY		169	170	1

8. WELL CONSTRUCTION
 Depth Drilled 170 Feet Depth Cased 170 Feet
 HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>8 3/4</u> Inches	<u>50</u> Feet	<u>170</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>72</u>	<u>170</u>

Perforations:
 Type perforation MILLED
 Size perforation 3 1/2
 From 150 feet to 170 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow NO G.P.M. 60 P.S.I.
 Water temperature 60.0 °F. Quality GOOD

Date started 4-21 1997
 Date completed 4-22 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60</u>	<u>60</u>	<u>4 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WATER DRILLING CO. INC
 Address 2220 STONE DR.
RENO NEVADA
 Nevada contractor's license number issued by the State Contractor's Board 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas M. Harris
 By driller performing actual drilling on site or contractor
 Date 4-22-97

RECEIVED
 97 MAY 12 AM 11:05
 STATE ENGINEERS OFFICE