WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67641
Permit No.
Basin #104

NOTICE OF INTENT NO. 344817

1. OWNER P. Cook
MAILING ADDRESS 4356 Kings Cyn Rd
Carson City, NV 89703
ADDRESS AT WELL LOCATION 4356 Kings Cyn Rd

2. LOCATION NW ¼ NE ¼ Sec. 23 T. 15 N/S R. 19 E. Carson City County
PERMIT NO. (Issued by Water Resources) Parcel No. Kings Cyn (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Mine Dump	X	0	40	40
Fill & Const Fill				
Hillside Debris		40	100	60
Talus, Vol w	Some Lt Brwn Clay			
Broken Vol w		100	200	100
AB Clay				
Brwn Clay w		200	280	80
Brwn & Blk Vol				
Brwn Clay w Blk		280	320	40
Gry Vol				
Altered Gry-Blk		320	340	20
Vol, Minor Cly				
Softer Altered	X	340	430	90
Vol Gry-Blk				
No Clay				
V Hard, Solid		430	455	25
To Fractured Gry				
Vol				

Date started 5/22, 1997
Date completed 6/4, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17	—	5½

8. WELL CONSTRUCTION
Depth Drilled 455 Feet Depth Cased 455 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17½ Inches		0 Feet	12 Feet
12¼ Inches		12 Feet	102 Feet
9⅞ Inches		102 Feet	455 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12¾		¼	+2	12
(Remove when Sealed)				
6⅝	13	.188	+2	455

Perforations:
Type perforation Sawcut
Size perforation 3X 3/32
From feet to feet
From 395 feet to 455 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 101 FT
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 101 feet to 455 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature COLD °F Quality ?

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling, Inc. (Contractor)
Address 75 Lewers Crk Rd (Contractor)
Carson City, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 136975A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Reisch (By driller performing actual drilling on site or contractor)
Date 7/31/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627