

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32640

1. OWNER Doug Reagan ADDRESS AT WELL LOCATION 1606 Scott Ln. Gardnerville NV 89423  
MAILING ADDRESS 1606 Scott Ln. Gardnerville NV 89423  
2. LOCATION SE 1/4 SE 1/4 Sec. 34 T. 13 N. R. 20 E. Douglas County  
PERMIT NO. 23-442-02 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sands		0	18	18
3/4 to 1/2 Gravel		18	63	45
Brown Clay Zone		63	91	28
Brown Clay seams		91	110	19
Coarse Sands w/ clay seams		110	140	30
Coarse Broken Gravel XX		140	160	20

8. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 3/4 Inches To 0 Feet 160 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<del>12.75</del>				
<u>6.98</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>160</u>

Perforations:  
Type perforation 2 1/2" Slot  
Size perforation 3 x 3/32  
From 140 feet to 160 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 100 feet to 160 feet

9. WATER LEVEL  
Static water level 25 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. 30+ P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Capital City Well Drilling Contractor  
Address 20 W. Kit Kat DR Carson City NV 89706 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 41775  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
Signed Michael J. Haek  
By driller performing actual drilling on site or contractor  
Date 6-30-97

Date started 6-25 1997  
Date completed 6-30 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>45</u>	<u>3 HRS</u>

RECEIVED  
97 JUL 17 PM 11:55  
STATE ENGINEER'S OFFICE