

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38315

1. OWNER Dr. THATCHER DILLEY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 935 Sierra Manor Way Corner Foothill Rd. & Eli Drive
Reno, Nevada 89511 Reno, Nevada 89511
 2. LOCATION SE 1/4 SE 1/4 Sec. 7 T. 18N N/S R. 20 E. Washoe County
 PERMIT NO. Letter July 30, 1997 044-361-10 Sierra Manor Subdivision SW Reno
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil with boulders		0	1	1
Sand & gravel & boulders		1	16	15
Sand & gravels w/boulders w/small brown clay streaks		16	55	39
Light rusty brown sandy clays		55	81	26
Brown clays w/streaks of sand & gravels		81	156	75
Volcanic boulder		156	158	2
Sand & gravels	X	158	161	3
Brown sandy clay		161	172	11
Sand & gravels	X	172	181	9
Volcanic boulder		181	184	3
Brown sandy clays some gravels		184	200	16

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 7/8 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 155 feet to 195 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 200 feet

Date started 8-12-97, 19____
 Date completed 8-15-97, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. 30+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC.
Contractor
 Address P.O. BOX 12370
Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources 923
 Signed [Signature] by driller performing actual drilling on site or contractor
 Date August 19, 1997