WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67919
Permit No.
Basin 92A

NOTICE OF INTENT NO. 33901

1. OWNER TOM & PAM JOHNSON
MAILING ADDRESS 11775 Osage
Reno NV 89506

ADDRESS AT WELL LOCATION SAME
Silver Knolls

2. LOCATION SE ¼ NE ¼ Sec. 13 T 21 N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 086-250-44 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN CLAY		1	16	15
BROWN SANDY CLAY		16	24	8
BROWN CLAY		24	69	45
BROWN SANDY CLAY		69	92	23
SOFT ZONE (corase sand)		92	96	4
BROWN SANDY CLAYS		96	180	84
MEDIUM CLAY	X	180	190	10
BROWN CLAY		190	211	21
MEDIUM SANDS	X	211	217	6
BROWN CLAY		217	221	4
CORASE SAND W/ gravels	X WB	221	227	6

97 JUL 24 AM 10:48
RECEIVED
STATE ENGINEER'S OFFICE

Date started July 17, 1997
Date completed July 18, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17		

8. WELL CONSTRUCTION
Depth Drilled 227 Feet Depth Cased 227 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	50
8 5/8	50	227

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	227

Perforations:
Type perforation Factory sawed slots
Size perforation 3/32 x 3x5 around
From 182 feet to 222 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 49
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 49 feet to 227 feet

9. WATER LEVEL
Static water level 133 feet below land surface
Artesian flow G.P.M. 17 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno NV 89510
Nevada contractor's license number issued by the State Contractor's Board 022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Gary Otterman (By driller performing actual drilling on site or contractor)
Date July 22, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627