

OFFICE USE ONLY
 Log No. 68020
 Permit No. _____
 Basin 44

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36603

1. OWNER MELYN MCGREW ADDRESS AT WELL LOCATION BLK 22 LOTS
 MAILING ADDRESS P.O. BOX 1076 CORNER S VAN BUREN BOHANGA RD
ELKO NV 89803

2. LOCATION SE 1/4 SW 1/4 Sec. 5 T. 35 N. R. 57 E ELKO County
 PERMIT NO. 026-022-005 RYNDON Subdivision Name MAR TRA #4
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	2	2
SAND Gravel		2	8	6
Brown SANDSTONE		8	56	48
CLAY		56	61	3
SANDSTONE Red	X	61	92	31
CLAY		92	97	5
Loose soft SANDSTONE	X	97	124	

8. WELL CONSTRUCTION
 Depth Drilled 124 Feet Depth Cased 124 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 224 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>1.55</u>	<u>72</u>	<u>124</u>

Perforations:
 Type perforation mill slot
 Size perforation 3/16 x 3"
 From 104 feet to 124 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 58 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 58 feet to 124 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started 8-15, 1997
 Date completed 8-15, 1997

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>APWA</u>	<u>52</u>		<u>2.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor
 Address P.O. Box 525 Contractor
ELKO NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031704
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shaul C Fertig
 By driller performing actual drilling on site or contractor
 Date 8-21-97