WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68058 pg1
Permit No.
Basin 071

NOTICE OF INTENT NO. 35018

1. OWNER Ether Westmoreland
MAILING ADDRESS PO Box 2550
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 3255 Ether Way
Winnemucca, NV 89445

2. LOCATION NE 1/4 NE SE 1/4 Sec. 24 T 35N N/S R 37 E Humboldt County
PERMIT NO. F-12 (Issued by Water Resources) Parcel No. 014-102-24 Westmoreland (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Sand & gravel		2	30	28
Cobbles w/sand & gravel		30	175	145

RECEIVED 97 APR 16 AM 11:53 STATE ENGINEER'S OFFICE

Designed under NOI 62659

N 40.890776
W 117.751657 NAD27

Date started 4/7/97, 19__
Date completed 4/7/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 7/8 Inches	0 Feet	175 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	170

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 150 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 170 feet

9. WATER LEVEL
Static water level 128 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 4-15-97

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68058 pg2
Permit No.
Basin 071

NOTICE OF INTENT NO. 35018

1. OWNER Ether Westmoreland
MAILING ADDRESS PO Box 2550
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
3255 Ether Way
Winnemucca, NV 89445

2. LOCATION ____ 1/4 NE 1/4 Sec. 24 T 35N N/S R 37 E Humboldt County
PERMIT NO. ____ Issued by Water Resources
F-12 Parcel No.
Westmoreland Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Sand & gravel		2	30	28
Cobbles w/sand & gravel		30	175	145

Date started 4/7/97 , 19__
Date completed 4/7/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	175	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	170

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 150 feet to 170 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 170 feet

9. WATER LEVEL
Static water level 128 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019
Signed ____ By driller performing actual drilling on-site or contractor
Date ____