

OFFICE USE ONLY
 Log No. 68177
 Permit No. _____
 Basin 54

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15782

1. OWNER Cortez Gold mines ADDRESS AT WELL LOCATION Frame Property
 MAILING ADDRESS HCB-50 Star Route
Beowawe, NV 89821
 2. LOCATION SW 1/4 NW 1/4 Sec. 13 T 28 R 47 E LANDER County
 PERMIT NO. m/o-1003 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ALLUVIUM</u>		<u>0</u>	<u>40</u>	<u>40</u>
<u>SAND PACK</u>		<u>40</u>	<u>10</u>	<u>30</u>
<u>Bentonite chips</u>		<u>10</u>	<u>8</u>	<u>2</u>
<u>Cement</u>		<u>8</u>	<u>0</u>	<u>8</u>

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 38 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 40 Feet
7 7/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>N/A</u>	<u>SCH-40</u>	<u>72</u>	<u>38</u>

Perforations:
 Type perforation Horz slot
 Size perforation 1020
 From SCREEN 38 feet to 18 feet
 From BLANK 18 feet to 72 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 7
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 40 feet to 10 feet

9. WATER LEVEL
 Static water level N/A feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I.
 Water temperature N/A °F Quality N/A

Date started 7/24 1997
 Date completed 7/25 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
	<u>N/A</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKLUND Drilling Co Contractor
 Address P.O. Box 2748 Contractor
EIKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1942
 Signed William Riley
 By driller performing actual drilling on site or contractor
 Date 7/25/97