WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68353
Permit No.
Basin 049

NOTICE OF INTENT NO. 30574

1. OWNER Harold Jatkola
MAILING ADDRESS 611 Bullion Road #60
Elko, NV 89801

ADDRESS AT WELL LOCATION So. Side of 34th St. between Yosemite & Jasper Ave.

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 34 N/S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) 64-001-04 (Parcel No.) MVR #9 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	17	17
Sand & Gravel	X	17	40	23
Brown Clay		40	65	25
Grey Shale		65	75	10
Sand & Coarse Gravel	X	75	100	25

Date started 3-25, 1996
Date completed 3-26, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [XX] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow Test	60		3 hrs

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	50 Feet
9-7/8 Inches		50 Feet	100 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1-1/2	100

Perforations:
Type perforation Millslot
Size perforation 3/16 x 3"
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 27 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-27-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627