WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68376
Permit No.
Basin

NOTICE OF INTENT NO. 36665

1. OWNER TIMET HENDERSON FACILITY
MAILING ADDRESS 8100 LAKE MEAD DR
HENDERSON, NV

ADDRESS AT WELL LOCATION 8100 LAKE MEAD DR
HENDERSON, NV

2. LOCATION NE ¼ SW ¼ Sec. 12 T 22 ~~N~~/S R. 62 E CLARK County
PERMIT NO. Issued by Water Resources 178 12 S01 007 / 178 Parcel No. 001 004 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELY FINE TO MEDIUM SAND WITH SOME SILT		0	26	
SILTY FINE TO MEDIUM SAND WITH A TRACE OF GRAVEL		26	38.5	
SILTY FINE SAND WITH A TRACE OF GRAVELS		38.5	42.5	
GRAVELY SILTY FINE SAND, BROWN		42.5	43.5	
SILTY SAND		43.5	44.5	
SANDY CLAY WITH SOME COURSE BROWN		44.5	53	
GRAVELLY FINE SAND		53	56.5	
SILTY CLAY, DARK YELLOWISH BROWN		56.5	70.5	

Date started 8/6/97, 19
Date completed 8/6/97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 69 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	0	35

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2.043	.237	0	35

Perforations:
Type perforation SCHEDULE 40
Size perforation .020
From 35 feet to 69 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 32
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 29 feet to 69 feet

9. WATER LEVEL
Static water level 39 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JOHN MANLEY
Address 3121 S. PARK DR TEMPE, AZ
THE VERDE COMPANIES
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the onsite driller M2070
Signed John Manley
By driller performing actual drilling on site or contractor
Date 10-3-97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627