

OFFICE USE ONLY  
 Log No. 68947  
 Permit No. \_\_\_\_\_  
 Basin 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16912

1. OWNER Maria Corlis ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 50443 1531 N. Dupont  
Henderson, NV 89016 Pahrump, NV  
 2. LOCATION SE 1/4 NW 1/4 Sec. 2 T. 20S N/S R. 53 E Nye County  
 PERMIT NO. 35-032-08 35-032-08 Green valley Acres Lot 39  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface (gravel)		0	7	7
Clay mostly w/small rocks in small layer		7	124	117
Large gravel & rocks	X	124	138	14
Brown clay w/rocks		138	167	29
Loose gravel (large)		167	175	8
Strips of cemented gravel w/areas of loose gravel & rocks	X	175	216	41

8. WELL CONSTRUCTION  
 Depth Drilled 216 Feet Depth Cased 216 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 216 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17#	.188	0	216

Perforations:  
 Type perforation Torch cut  
 Size perforation 1/4" wide, 8" long  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 176 feet to 216 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50'  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 130 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Well Drilling  
 Address 1060 W. Basin Rd.  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board 7484  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725  
 Signed Charles Nyberg  
 By driller performing actual drilling on site or contractor  
 Date Oct 13, 1997

Date started 10-8-97 19\_\_\_\_  
 Date completed 10-11-97 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>-0-</u>	<u>15 min</u>