

OFFICE USE ONLY
 Log No. 68800
 Permit No. _____
 Basin 137B
 NOTICE OF INTENT NO. 32940

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER GARY LYMAN ADDRESS AT WELL LOCATION 110 GILLMAN CIRCLE - GILLMAN SPRINGS
 MAILING ADDRESS H.C. 65 Box 45 AUSTIN NEV 89310
GILLMAN SPRINGS AUSTIN NEV 89310
 2. LOCATION SE 1/4 NW 1/4 Sec 10 T 16 N/S R 44 E LANDER County
 PERMIT NO. 01-033-08 Parcel No. GILLMAN SPRINGS RANCH Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN CLY		0	12	12
SMALL GRAVEL		12	15	3
BRN CLY		15	30	15
SMALL GRAVEL		30	38	8
LT TAN CLY		38	75	37
SMALL GRAVEL		75	78	3
YELLOW CLY		78	85	7
GRAVEL	Y	85	91	6
YELLOW TO WHITE CLY		91	118	27
MOSTLY GRAVEL WITH CLY	Y	118	140	22
STAINERS				
WHITE CLY & GRAVEL		140	148	8
GRAVEL	Y	148	155	7
YELLOW CLY		155	160	5

RECEIVED
 9 MAY 12 AM 11:05
 STATE ENGINEERING DIVISION

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation MILLED
 Size perforation 1/8 x 3"
 From 120 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 30 feet below land surface
 Artesian flow NO G.P.M. 40 P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 4-16 1997
 Date completed 4-17 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>30</u>	<u>7 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOYTEK DRILLING CO. INC Contractor
 Address 2220 STONE DR Contractor
RENO NEVADA 89511
 Nevada contractor's license number issued by the State Contractor's Board 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas M. Harris
 By driller performing actual drilling on site or contractor
 Date 4-18-97