

OFFICE USE ONLY  
 Log No. 168807  
 Permit No. \_\_\_\_\_  
 Basin 137B  
 NOTICE OF INTENT NO. 31364

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER CARSTEN REESE ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS HC 65 BOX 55 108 GILLMAN CIRCLE  
GILLMAN SPRINGS AUSTIN NEV 89310 GILLMAN SPRINGS AUSTIN NEV 89310  
 2. LOCATION SE 1/4 NW 1/4 Sec. 10 T. 16 N/S R. 44 E LANDER County  
 PERMIT NO. 04-033-23 GILLMAN SPRINGS RANCH Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLY		0	12	12
GRAVEL		12	18	6
BROWN CLY		18	25	7
SMALL GRAVEL		25	34	9
TAN CLY		34	90	56
GRAVEL	X	90	93	3
TAN CLY		93	143	50
GRAVEL	X	143	159	16
WHITE CLY		159	160	1

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>72</u>	<u>160</u>

Perforations:  
 Type perforation MILLED  
 Size perforation 3 1/8  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow NO G.P.M. 20 P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WOYTEK DRILLING CO INC Contractor  
 Address 2220 STONE DR Contractor  
RENO NEVADA 89511  
 Nevada contractor's license number issued by the State Contractor's Board 024521A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
 Signed Thomas M. Plausis  
 By driller performing actual drilling on site or contractor  
 Date 4-22-97

Date started 4-17 1997  
 Date completed 4-21 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>N/A.</u>	<u>7 Hrs</u>

RECEIVED  
 97 MAY 12 AM 11:05  
 STATE ENGINEERING OFFICE