

OFFICE USE ONLY
 Log No. 108810
 Permit No. _____
 Basin. 105

28482

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28482
 ADDRESS AT WELL LOCATION 1919 CURRANT CT. GARDNERVILLE, NV

1. OWNER MOLINE BUILDERS ADDRESS AT WELL LOCATION 1919 CURRANT CT. GARDNERVILLE, NV
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION NW 1/4 NE 1/4 Sec 1 T 12 N R 20 E DOUGLAS County
 PERMIT NO. 23-480-71 WILDFLOWER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	14	14
SANDY CLAY		14	37	23
SAND + GRAVEL		37	114	
SANDY CLAY		114	118	4
SAND + GRAVEL		118	130	12
SANDY CLAY w/GRAVEL		130	155	25
SANDY CLAY		155	198	43
SANDY CLAY w/GRAVEL		198	210	12
SANDY CLAY		210	254	44
FRACTURED BASALT		254	322	68
CLAY		322	331	9
SAND	✓	331	334	3
CLAY		334	346	12
SAND	✓	346	349	3
SANDY CLAY		349	380	31
GRAY CLAY		380	392	12
SAND	✓	392	408	16
GRAY CLAY		408	410	2

8. WELL CONSTRUCTION
 Depth Drilled 410 Feet Depth Cased 410 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 410 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>410</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 1/8 x 3
 From 330 feet to 350 feet
 From 390 feet to 410 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 410 feet

9. WATER LEVEL
 Static water level: 190 feet below land surface
 Artesian flow: _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 2/18 1997
 Date completed 3/5 1997

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>6</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 879 RITTER DR. GARDNERVILLE, NV 89410 Contractor
 Nevada contractor's license number issued by the State Contractor's Board: 27673A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1726
 Signed Paul J. Moore
 By driller performing actual drilling on site or contractor
 Date 3/5/97

RECEIVED
 97 APR 16 AM 11:28
 STATE ENGINEERS OFFICE