

OFFICE USE ONLY
 Log No. 68818
 Permit No. _____
 Basin 049

NOTICE OF INTENT NO. 82030

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER ROBERTO RIZO ADDRESS AT WELL LOCATION None
 MAILING ADDRESS 161 Copper St. Elko, NV 89801

2. LOCATION NE 1/4 SW 1/4 Sec. 3 T. 35 N/S R. 56 E. ELKO County
 PERMIT NO. _____ Issued by Water Resources Parcel No. Lot 8, Blk 9 Meadow Valley R. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay		0	40	40
Gravel (loose)	✓		40	44
Sandy clay		44	128	84
Sand & gravel	✓	128	132	4
clay		132	140	8
Gravel	✓✓	140	143	3
clay		143	148	5
Gravel	✓	148	152	4
clay		152	158	6
		T.D.	158	

8. WELL CONSTRUCTION
 Depth Drilled 158 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 55 Feet
8 Inches 55 Feet 158 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>158</u>

Perforations:
 Type perforation Torch cut
 Size perforation 1/8 x 5

From _____ feet to _____ feet
 From 118 feet to 155 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 55 feet to 158 feet

Date started 3-26, 1996
 Date completed 3-30, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>25</u>	<u>2</u>

9. WATER LEVEL
 Static water level 38 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MUTH DRILLING Co. Contractor
 Address 203 PINE ST Contractor
ELKO, NV 89800

Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632

Signed James V. Muth
 By driller performing actual drilling on site or contractor
 Date A-15-96