

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35632

1. OWNER Bill Betts si ADDRESS AT WELL LOCATION 2730 EAST 10th Street SILVER SPRINGS, NV. 89429  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NW 1/4 NE 1/4 Sec. 20 T. 17 N/S R. 25 E County \_\_\_\_\_  
 PERMIT NO. 17-471-13 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	8	8
Sand, coarse		8	13	5
Sand, fine		13	23	10
Clay		23	29	6
Sand		29	31	2
Clay		31	36	5
Shale		36	42	6
Clay		42	45	3

8. WELL CONSTRUCTION  
 Depth Drilled 145 Feet Depth Cased 145 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 1 1/4 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>145</u>

RECEIVED  
 97 AUG 13 AM 11:22  
 STATE ENGINEER'S OFFICE

Perforations:  
 Type perforation Tapered  
 Size perforation 3 1/2 x 1 1/2 x 6 #  
 From 138 feet to 143 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 80 feet to 145 feet

Date started 7/29, 19\_\_\_\_  
 Date completed 7/30/97, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20-23</u>	<u>1 1/2</u>	<u>1 1/2</u>

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Green Drilling Co Contractor  
 Address P.O. 599 Contractor  
SS NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1856  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7/31/97