WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69452
Permit No.
Basin 212

NOTICE OF INTENT NO. 17438

1. OWNER City of Henderson
MAILING ADDRESS 240 Water St
Henderson, NV 89015

ADDRESS AT WELL LOCATION 200 Athens
Henderson, NV 89015

2. LOCATION South ½ SW ¼ Sec. 36 T. 21 S N/S R. 62 E Clark County
PERMIT NO. DW-1077 Issued by Water Resources
161-36-701-001 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock
Dewatering

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Dry Silty Clay | | 0 | 20' | 20' |
| Silty Sand | | 20' | 28' | 8' |
| Silty Clay with Rocks | | 28' | 29' | 1' |
| Brown Clay | | 29' | 34' | 5' |
| Whitish-Green Clay | | 34' | 39' | 5' |
| White Clay | | 39' | 40' | 1' |

Date started 12-4, 1997
Date completed 12-4, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 35' Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 24" Inches | | 0 Feet | 40' Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8" | PVC | | 0 | 15 |
| | | | | |
| | | | | |

Perforations:
Type perforation Saw cut
Size perforation .032
From 15 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40' feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering Contractor
Address 536 E Maitland St Contractor
Ontario CA 91761
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1985
Signed By driller performing actual drilling on site or contractor
Date 12-4-97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627