


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 69651
 Permit No. 162
 Basin



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15550

OWNER Strickland Construction ADDRESS AT WELL LOCATION 3610 Sagebrush
 MAILING ADDRESS 3610 Sagebrush
Pahrump, NV 89048

2. LOCATION NE 1/4 SW 1/4 Sec. 31 T 20S N/S R 54E E Nye County
 PERMIT NO. 41-143-122 Parcel No. Subdivision Name Calvada Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
		0		
SANDY LOAM		0	8	8
BROWN CLAY		8	19	11
BROWN CALACHE		19	35	16
BROWN CLAY		35	40	5
LIGHT BROWN CLAY		40	45	5
LIGHT GREY CLAY		45	62	17
BROWN CALACHE		62	90	28
BROWN CALACHE	X	90	103	13
GREY CLAY	X	103	119	16
BROWN CLAY	X	119	138	19
BROWN CLAY	X	138	150	12

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 7/8 Inches 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	150

Perforations:
 Type perforation SAW-CUT
 Size perforation .188

From 110 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 150 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 10/9/97 19____
 Date completed 10/9/97 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>.5</u>	<u>na</u>	<u>.50</u>


Name Strickland Construction Co., inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed
 By driller performing actual drilling on-site or contractor

Date 10-11-97

KC