

OFFICE USE ONLY  
 Log No. 69903  
 Permit No. 105  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36053

1. OWNER DONALD E. BENTLEY ADDRESS AT WELL LOCATION SOUTH RANCH  
 MAILING ADDRESS P.O. BOX 127  
MINDEN, NV 89423  
 2. LOCATION SW 1/4 NW 1/4 Sec. 21 T. 12 N3 R. 20 E DOUGLAS County  
 PERMIT NO. PROF. 07309 VESTED RIGHT  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY, SAND, GRAVEL, COBBLES		0	6	6
SAND, GRAVEL, COBBLES		6	15	9
COARSE SAND		15	18	3
BLACK, WHITE, BROWN ROCK		18	20	2
WHITE SAND		20	22	2
BLACK WHITE BROWN ROCK		22	75	53
COARSE SAND		75	85	10
BLACK, BROWN WHITE GREEN ROCK		85	100	15
BROWN, BLACK ROCK		100	110	10
BLACK, BROWN, WHITE ROCK		110	172	62
BLACK, BROWN, ROCK AND SAND		172	205	33

8. WELL CONSTRUCTION  
 Depth Drilled 205 Feet Depth Cased 203 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
14 3/4 Inches 0 Feet 205 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.79	.188	+2	53

Perforations:  
 Type perforation MILL SLOT  
 Size perforation 3" X 1/8"  
 From 53 feet to 203 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 203 feet  
 9. WATER LEVEL  
 Static water level 50 per telcom w/ sargent feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality GOOD

Date started NOVEMBER 20, 1997  
 Date completed NOVEMBER 25, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>75</u>		<u>7.5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SARGENT IRRIGATION COMPANY  
 Contractor  
 Address 9955 NORTH VIRGINIA STREET  
 Contractor  
RENO, NEVADA 89506  
 Nevada contractor's license number 0021264  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1593  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date NOVEMBER 25, 1997