



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15221

1. OWNER Charles & Christina Eaton ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11900 Blue Diamond Rd
89124
 2. LOCATION SW 1/4 NE 1/4 Sec 16 T. 22 N. 0.59 E Clark County _____
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. 1751660/007 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Galvanite</u>		<u>0</u>	<u>10</u>	
<u>Sand Gravel Boulder</u>		<u>10</u>	<u>105</u>	
<u>Red Sandstone</u>		<u>105</u>	<u>115</u>	
<u>Sand Gravel Boulder</u>		<u>115</u>	<u>245</u>	
<u>Red Sandstone</u>		<u>245</u>	<u>345</u>	
<u>Yellow Sandstone</u>		<u>345</u>	<u>360</u>	
<u>Red Sandstone</u>		<u>360</u>	<u>390</u>	
<u>Sand Gravel Boulder</u>		<u>390</u>	<u>450</u>	
<u>Red Sandstone</u>		<u>450</u>	<u>475</u>	
<u>Sand Gravel Boulder</u>		<u>475</u>	<u>600</u>	
<u>Same</u>		<u>600</u>	<u>700</u>	
<u>lime stone</u>		<u>700</u>	<u>750</u>	
<u>lime stone</u>	<u>50</u>	<u>750</u>	<u>800</u>	

8. WELL CONSTRUCTION
 Depth Drilled 810 Feet Depth Cased 805 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10' Inches 0 Feet 810 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12</u>	<u>1.88</u>	<u>+2</u>	<u>805</u>

Perforations:
 Type perforation Jet
 Size perforation 1/8
 From 740 feet to 805 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-50 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 805 feet

9. WATER LEVEL
 Static water level 245 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality Good

Date started 12-24 1997
 Date completed 12-8 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Rudolph R. Riddling Contractor
 Address 8170 Haven Contractor
LV NV 89123
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller _____
 Signed William R. Riddling
 By driller performing actual drilling on site of contractor
 Date 12-11-97

