

Log No. 70060 70060
 Permit No. 153
 Basin 153

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 347108

1. OWNER XX EUREKA COUNTY PUD ADDRESS AT WELL LOCATION Hwy 50 & Parker St EUREKA, NV
 MAILING ADDRESS PO 257 EUREKA, NV 89316
 2. LOCATION SW 1/4 Sec 13 T 19 R 53 E EUREKA County
 PERMIT NO. MO 1088-A 01-036-05 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>MW-7</u>				
<u>ASPHALT</u>		<u>0'</u>	<u>3"</u>	
<u>GRAVELLY CLAY</u>		<u>3"</u>	<u>5'</u>	
<u>SANDY CLAY</u>		<u>5'</u>	<u>16'</u>	
W 395108-1				
W 11576753-2 NADSD				
W 11576753-3 NADSD				
W 11576753-4 NADSD				
W 11576753-5 NADSD				
W 11576753-6 NADSD				
W 11576753-7 NADSD				
W 11576753-8 NADSD				
W 11576753-9 NADSD				
W 11576753-10 NADSD				
W 11576753-11 NADSD				
W 11576753-12 NADSD				
W 11576753-13 NADSD				
W 11576753-14 NADSD				
W 11576753-15 NADSD				
W 11576753-16 NADSD				
W 11576753-17 NADSD				
W 11576753-18 NADSD				
W 11576753-19 NADSD				
W 11576753-20 NADSD				

8. WELL CONSTRUCTION
 Depth Drilled 16 Feet Depth Cased 15.5' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 16 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.37</u>		<u>SCH 40</u>	<u>0</u>	<u>5.5</u>

Perforations:
 Type perforation SCREEN
 Size perforation 200
 From 5.5 feet to 15.5 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 0-2' CON / 2'-4' BENT. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 BENT. CHIPS
 Gravel Packed: Yes No
 From 4 feet to 16 feet

9. WATER LEVEL
 Static water level 7.5" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6.17 1997
 Date completed _____ 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING TOOL Contractor
 Address 75 LEWORS CREEK ROAD Contractor
CARSON CITY NV 89704
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1902
 Division of Water Resources, the on-site driller.
 Signed John S. Jones
 By driller performing actual drilling on site or contractor
 Date 9.10.97