WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. [redacted] 70297
Permit No. 91
Basin

NOTICE OF INTENT NO. 26207

1. OWNER Gold Ranch Casino
MAILING ADDRESS 350 Interstate 80 Verdi, NV
ADDRESS AT WELL LOCATION Gold Ranch Casino, 350 Interstate 80 Verdi, NV

2. LOCATION NW ¼ NE ¼ Sec. ~~09T~~19 T N19 N/S R E18 E ~~19AB~~ County
PERMIT NO. M/O-968-B (Issued by Water Resources) 038-230-23 (Parcel No.) APN 038-230-23 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey Sand Brown		~~0~~	3	3
Silty Sand with gravels - Brown		3	15	12
Sandy gravel with Boulders - Brown		15	21	6
Silty Sands with fine gravels - Brown		21	26	5
Sandy gravels + boulders light Brown		26	33	7
Sandy gravel light brown		33	35	2
Silty Sandy gravels dark brown		35	55	20

Well # SVE S-2

Date started 10-3-96, 19
Date completed 10-4-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 55 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)
8 5/8 Inches From ~~0~~ Feet To 55 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1"		Sch 40	~~0~~	55
4"		Sch 40	~~0~~	35

Perforations:
Type perforation 1" slot + 4" slot
Size perforation 1" + 4" .020
From 1"-53 feet to 55 feet
From 4"-10 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 8 feet to 55 feet

9. WATER LEVEL
Static water level 40.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Western Strata Exploration (Contractor)
Address P.O. Box 1664 (Contractor)
West Sacto, CA 95691
Nevada contractor's license number issued by the State Contractor's Board C230034236A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1937
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-5-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627